




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TWW 37



55 °C

35 °C




**A++**

**A++**



50 dB



- dB

■ 32  
■ **32**  
■ 32  
kW

■ 36  
■ **36**  
■ 36  
kW



2015

811/2013

**TWW 37**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	179	233
$P_{rated}$ [kW]	32	36
$Q_{HE}$ [kWh/y]	16544	12639
SCOP [-]	4.47	5.83
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	157	232
$P_{rated}$ [kW]	32	36
$Q_{HE}$ [kWh/y]	22649	15286
SCOP [-]	3.92	5.80
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	231	231
$P_{rated}$ [kW]	32	36
$Q_{HE}$ [kWh/y]	8195	8173
SCOP [-]	5.77	5.78
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓