




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TWW 89



55 °C

35 °C



**A++**

**A++**



56 dB



- dB

■ 78  
■ **78**  
■ 78  
kW

■ 89  
■ **89**  
■ 89  
kW



2015

811/2013

**TWW 89**

**ErP Data**

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	173	227
$P_{rated}$ [kW]	78	89
$Q_{HE}$ [kWh/y]	42260	32253
SCOP [-]	4.33	5.67
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	152	225
$P_{rated}$ [kW]	78	89
$Q_{HE}$ [kWh/y]	57876	38987
SCOP [-]	3.79	5.62
$T_{bivalent}$ [°C]	-7	-10

	55 °C	35 °C
Energy class	<b>A++</b>	<b>A++</b>
$\eta$ [%]	226	226
$P_{rated}$ [kW]	78	89
$Q_{HE}$ [kWh/y]	20910	20857
SCOP [-]	5.64	5.66
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓