


**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK** TBW 66

---





55 °C

**A++**


35 °C

**A++**






**54** dB



- dB

■ 62	■ 66
■ <b>62</b>	■ <b>66</b>
■ 62	■ 66
kW	kW



2015

811/2013

		ErP Data	
		55 °C	35 °C
Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		143	191
$P_{rated}$ [kW]		62	66
$Q_{HE}$ [kWh/y]		38179	28488
SCOP [-]		3.57	4.77
$T_{bivalent}$ [°C]		-8	-10



  

Energy class		<b>A+</b>	<b>A++</b>
$\eta$ [%]		123	190
$P_{rated}$ [kW]		62	66
$Q_{HE}$ [kWh/y]		52945	34352
SCOP [-]		3.08	4.74
$T_{bivalent}$ [°C]		-8	-10

Energy class		<b>A++</b>	<b>A++</b>
$\eta$ [%]		190	190
$P_{rated}$ [kW]		62	66
$Q_{HE}$ [kWh/y]		18460	18423
SCOP [-]		4.75	4.76
$T_{bivalent}$ [°C]		-	-

CONTROLLER			
			
	+ QAA55/75	class VII	3.5% ↓
	- QAA55/75	class III	1.5% ↓