



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

TBW 50 EVI



55 °C

35 °C



A++

A++



54 dB



- dB

■ 50
■ **50**
■ 50
kW

■ 49
■ **49**
■ 49
kW



2015

811/2013

TBW 50 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	152	190
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	26182	20932
SCOP [-]	3.81	4.76
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	136	190
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	35351	25240
SCOP [-]	3.39	4.74
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	190	190
P_{rated} [kW]	50	49
Q_{HE} [kWh/y]	13552	13536
SCOP [-]	4.74	4.74
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓