




ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

TWWi 75



55 °C

35 °C




A++

A++



58 dB



- dB

■ 65
■ **65**
■ 65
kW

■ 75
■ **75**
■ 75
kW



2015

811/2013

TWWi 75

ErP Data

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 180 | 235 |
| P_{rated} [kW] | 65 | 75 |
| Q_{HE} [kWh/y] | 34189 | 26118 |
| SCOP [-] | 4.49 | 5.87 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 157 | 232 |
| P_{rated} [kW] | 65 | 75 |
| Q_{HE} [kWh/y] | 46804 | 31589 |
| SCOP [-] | 3.92 | 5.81 |
| $T_{bivalent}$ [°C] | -7 | -10 |

| | 55 °C | 35 °C |
|---------------------|------------|------------|
| Energy class | A++ | A++ |
| η [%] | 233 | 234 |
| P_{rated} [kW] | 65 | 75 |
| Q_{HE} [kWh/y] | 16934 | 16890 |
| SCOP [-] | 5.83 | 5.84 |
| $T_{bivalent}$ [°C] | - | - |

CONTROLLER



| | | |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |