



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

TBW 50i



55 °C

35 °C



A++

A++



54 dB



- dB

■ 48
■ **48**
■ 48
kW

■ 51
■ **51**
■ 51
kW



2015

811/2013

TBW 50i

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	142	191
P_{rated} [kW]	48	51
Q_{HE} [kWh/y]	29471	21990
SCOP [-]	3.56	4.77
$T_{bivalent}$ [°C]	-8	-10

	A+	A++
Energy class	A+	A++
η [%]	123	190
P_{rated} [kW]	48	51
Q_{HE} [kWh/y]	40870	26517
SCOP [-]	3.08	4.74
$T_{bivalent}$ [°C]	-8	-10

	A++	A++
Energy class	A++	A++
η [%]	190	190
P_{rated} [kW]	48	51
Q_{HE} [kWh/y]	14249	14221
SCOP [-]	4.74	4.75
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓